



Community Development Department
On-Site Division
300 NE 3rd Street, Room 12
Prineville, OR 97754
(541)447-8155 Fax (541)416-2139
Email: OnSite@co.crook.or.us
Website: www.co.crook.or.us

TANK ABANDONMENT PROCEDURES

- Instructions: The tank(s) contents must be pumped completely empty by a licensed sewage disposal service. Attach a copy of the pumper's receipt to this form.
Select ONE of the following 3 options:
A. Removal: Check with the local landfill or local recycler before transporting the old tank.
B. Fill in place: The top of the tank shall be removed before filling.
C. Crush and bury: After pumping the tank, crush the tank so that there are no void areas.
Request Inspection: To request an inspection, the following must be completed:
- Check the appropriate boxes above,
- fill out the location and permit # below,
- attach a copy of the receipt from the pumper,
- and sign and turn in this form.
You may turn this information in to the Bend, Redmond, or La Pine location office.

Septic Permit # \_\_\_\_\_ Contact Name: \_\_\_\_\_ Contact Phone # \_\_\_\_\_
Job Site Address \_\_\_\_\_ City/State/Zip \_\_\_\_\_

I certify that the above information is true and complete to the best of my knowledge and that the decommissioning of this septic system on the above stated lot has taken place in accordance with the above procedures and the OAR 340-71-0185 requirements.

Contractor's Signature \_\_\_\_\_

Remember to attach a copy of the pumper's receipt with this form.

Note: Components of the Decommissioned System

Drainfields can be left intact but they should not be excavated for a year after the last use. Distribution boxes should be pumped out by a licensed pumper and removed or filled in location. Sand Filter mounds can be left in place, but if removed, they should not be excavated for a year after the last use.